

ADDENDUM 001

REQUEST FOR QUOTATION Concrete Brine Containment RFQ KC-Q11-007

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. **The due date for receipt of bid remains the same with the bid due back on September 8, 2011, by 1:00 PM CST.** Accordingly, the following clarifications are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Robin Warren Sr. Procurement Agent
Bidder/Offeror Signature _____ (Signature of person authorized to sign)	Department of Transportation <i>Robin Warren</i> _____ (Authorizing Signature)
Date Signed:	Date Signed: September 2, 2011

NOTES: The following information is for additional clarification of Attachment B in the original bid document.

- The entire pad is 75' X 32'
- The containment area is 49' X 31' (Inside measurements)
- A footing will only be placed under the containment area
- The walls for the containment will set on top of the pad over the keyway and they will be 4' X 6"